



The York Water Company  
Public Comment for the Pennsylvania Department of Environmental Protection  
Regarding Proposed Changes to Technical Guidance Document  
(25 Pa. Code Chapter 109)  
Water Quality Parameter Reporting Instructions for The Lead and Copper Rule  
Document Number 393-0300-008  
December 20, 2018

Comments on Document Number 393-0300-008

Titled Water Quality Parameter Reporting Instructions for the Lead and Copper Rule

- 1) Page 10, Table: WQP Codes and Methods: The table seems confusing and in our opinion could use clarification. The WQP Name: "Temperature" does not have an asterisk next to it, suggesting that it *may not* be measured in the field. However, I believe that this analyte *must* be measured in the field. Our suggestion would be to either:
  - a. Insert a double asterisk and a reference below the table indicating that Temperature *must* be measured in the field (as opposed to a single asterisk indicating, "may be measured in the field")
    - i. or –
  - b. Insert a single asterisk indicating that it also "may be measured in the field".

Also, please reference page 13 in Document 393-0300-001, 5<sup>th</sup> bullet from the bottom of the page stating, "Measure temperature in the field".

Thank you for your consideration,

Douglas J. Crawshaw  
Water Quality Manager  
The York Water Company  
130 E. Market St.  
York, PA 17401

E: [dougc@yorkwater.com](mailto:dougc@yorkwater.com)

D: (717) 718-2974

M: (717) 801-7230

[www.yorkwater.com](http://www.yorkwater.com)

NASDAQ: YORW